

Product data sheet Spirotech

Product name

SpiroVent -1¼" -Hor -HighT

Article number

AA125/002

Product properties


A brass (microbubble) deaerator for high-temperature systems (max. 180 °C), with a 22 mm - 1½" horizontal connection

- Removes all circulating air and microbubbles effectively
- Applicable with 50/50 Glycol / Water (Volume)
- Applicable for high temperature system configurations
- Removes trapped air when installed at the correct location
- Greatly reduces the need for manual venting
- Constant low-pressure drop
- No unnecessary shutdown
- Connection diameters from 22 mm to 1½" (G1½)
- Exceptional guarantee

Product image



Product dimensions



Product data sheet Spirotech

ETIM product data

| | | | |
|---------------------------------|--|---------------------------------------|--------------|
| Housing material | Brass | Article compression class | PN 10 |
| With drain valve | No | Surface protection | Untreated |
| Housing material quality | Other | Suitable for open system | No |
| Backwash filter | No | Suitable for closed system | Yes |
| Medium temperature (continuous) | 0 - 180 °C | Suitable for solar | No |
| Max. operating pressure | 10 bar | With dismountable filter | No |
| Kvs value | 31.57 | Filter volume | 0.25 l |
| Variable flow direction | Yes | Magnet operating principle | No |
| With insulation | No | With automatic de-aerator | Yes |
| Separator type | Air | With integrated replenishment automat | No |
| Connection | Internal thread cylindrical BSPT-Rp (ISO 7-1 / EN 10226-1) | With couplers | Yes |
| Model | Horizontal | Material of connection | Brass |
| Nominal diameter | 1 1/4 inch (32) | Inlet/outlet offset distance | 0 mm |
| Max. glycol mixture | 50 % | Material quality connection | Other |
| Suitable for heating | Yes | Flow-through capacity | 0 - 3.6 m³/h |
| Suitable for cooling | Yes | Operating principle | Other |
| Construction length | 88 mm | | |

Disclaimer

This product sheet has been compiled with the greatest possible care. Nevertheless, it may contain errors or omissions. For the most current and correct information we refer you to our website.

